

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): August-25

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
8/1/2025	1st User for PH and EP-A for Alkalinity	7.7	27.0			Yes
8/2/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
8/3/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
8/4/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
8/5/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
8/6/2025	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
8/7/2025	1st User for PH and EP-A for Alkalinity	7.8	26.7			Yes
8/8/2025	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
8/9/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/10/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/11/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
8/12/2025	1st User for PH and EP-A for Alkalinity	7.8	26.9			Yes
8/13/2025	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
8/14/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
8/15/2025	1st User for PH and EP-A for Alkalinity	7.8	26.1			Yes
8/16/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/17/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/18/2025	1st User for PH and EP-A for Alkalinity	7.7	25.8			Yes
8/19/2025	1st User for PH and EP-A for Alkalinity	7.7	25.8			Yes
8/20/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
8/21/2025	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
8/22/2025	1st User for PH and EP-A for Alkalinity	7.8	26.9			Yes
8/23/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/24/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/25/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
8/26/2025	1st User for PH and EP-A for Alkalinity	7.8	26.7			Yes
8/27/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
8/28/2025	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
8/29/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
8/30/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/31/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes

Total number of excursions for PH during this monitoring period =

0

Total number of excursions for Alkalinity during this monitoring period =

0


Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:

Print Name:

Date:


 Troy N. Trute
 9/8/2025