

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): September-25

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
9/1/2025	1st User for PH and EP-A for Alkalinity	7.7	26.5			Yes
9/2/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
9/3/2025	1st User for PH and EP-A for Alkalinity	7.7	26.4			Yes
9/4/2025	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
9/5/2025	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
9/6/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
9/7/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
9/8/2025	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
9/9/2025	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
9/10/2025	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
9/11/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
9/12/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
9/13/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
9/14/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
9/15/2025	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
9/16/2025	1st User for PH and EP-A for Alkalinity	7.8	25.7			Yes
9/17/2025	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
9/18/2025	1st User for PH and EP-A for Alkalinity	7.8	26.2			Yes
9/19/2025	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
9/20/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/21/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/22/2025	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
9/23/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
9/24/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
9/25/2025	1st User for PH and EP-A for Alkalinity	7.8	26.1			Yes
9/26/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
9/27/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/28/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/29/2025	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
9/30/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes

Total number of excursions for PH during this monitoring period =

0

Total number of excursions for Alkalinity during this monitoring period =

0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:

Print Name:

Date:


 Troy N. Trute
 10/7/2025