

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): November-25

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
11/1/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/2/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/3/2025	1st User for PH and EP-A for Alkalinity	7.7	26.5			Yes
11/4/2025	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
11/5/2025	1st User for PH and EP-A for Alkalinity	7.7	26.4			Yes
11/6/2025	1st User for PH and EP-A for Alkalinity	7.7	27.0			Yes
11/7/2025	1st User for PH and EP-A for Alkalinity	7.7	27.2			Yes
11/8/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/9/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/10/2025	1st User for PH and EP-A for Alkalinity	7.7	26.6			Yes
11/11/2025	1st User for PH and EP-A for Alkalinity	7.7	26.6			Yes
11/12/2025	1st User for PH and EP-A for Alkalinity	7.7	26.3			Yes
11/13/2025	1st User for PH and EP-A for Alkalinity	7.7	26.8			Yes
11/14/2025	1st User for PH and EP-A for Alkalinity	7.7	27.0			Yes
11/15/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/16/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
11/17/2025	1st User for PH and EP-A for Alkalinity	7.6	27.0			Yes
11/18/2025	1st User for PH and EP-A for Alkalinity	7.7	27.1			Yes
11/19/2025	1st User for PH and EP-A for Alkalinity	7.7	27.3			Yes
11/20/2025	1st User for PH and EP-A for Alkalinity	7.7	26.8			Yes
11/21/2025	1st User for PH and EP-A for Alkalinity	7.7	26.5			Yes
11/22/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/23/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/24/2025	1st User for PH and EP-A for Alkalinity	7.7	26.2			Yes
11/25/2025	1st User for PH and EP-A for Alkalinity	7.7	26.4			Yes
11/26/2025	1st User for PH and EP-A for Alkalinity	7.7	26.7			Yes
11/27/2025	1st User for PH and EP-A for Alkalinity	7.8	26.6			Yes
11/28/2025	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
11/29/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
11/30/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes

Total number of excursions for PH during this monitoring period =

0

Total number of excursions for Alkalinity during this monitoring period =

0


Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:

Print Name:

Date:



Troy N. Trute

12/5/2025