

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): January-26
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
1/1/2026	1st User for PH and EP-A for Alkalinity	7.8	27.2			Yes
1/2/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
1/3/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/4/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/5/2026	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
1/6/2026	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
1/7/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
1/8/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
1/9/2026	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
1/10/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/11/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/12/2026	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
1/13/2026	1st User for PH and EP-A for Alkalinity	7.8	27.2			Yes
1/14/2026	1st User for PH and EP-A for Alkalinity	7.8	26.6			Yes
1/15/2026	1st User for PH and EP-A for Alkalinity	7.8	26.7			Yes
1/16/2026	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
1/17/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/18/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/19/2026	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
1/20/2026	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
1/21/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
1/22/2026	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
1/23/2026	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
1/24/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/25/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/26/2026	1st User for PH and EP-A for Alkalinity	7.8	27.1			Yes
1/27/2026	1st User for PH and EP-A for Alkalinity	7.8	26.7			Yes
1/28/2026	1st User for PH and EP-A for Alkalinity	7.8	26.9			Yes
1/29/2026	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
1/30/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
1/31/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 2/6/2026