

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**

**PWS Name/ID:** Neskowin Reg Water Dist - 4100970  
**Sample Period (Month/Year):** February-26  
**Required Sample Frequency:** Ph Every Day  
**Required Sample Frequency:** Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
2/1/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/2/2026	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
2/3/2026	1st User for PH and EP-A for Alkalinity	7.8	27.2			Yes
2/4/2026	1st User for PH and EP-A for Alkalinity	7.8	27.1			Yes
2/5/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
2/6/2026	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
2/7/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/8/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/9/2026	1st User for PH and EP-A for Alkalinity	7.8	27.1			Yes
2/10/2026	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
2/11/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
2/12/2026	1st User for PH and EP-A for Alkalinity	7.7	26.9			Yes
2/13/2026	1st User for PH and EP-A for Alkalinity	7.7	27.0			Yes
2/14/2026	1st User for PH and EP-A for Alkalinity	7.7				Yes
2/15/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/16/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
2/17/2026	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
2/18/2026	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
2/19/2026	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
2/20/2026	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
2/21/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/22/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/23/2026	1st User for PH and EP-A for Alkalinity	7.7	27.3			Yes
2/24/2026	1st User for PH and EP-A for Alkalinity	7.7	27.4			Yes
2/25/2026	1st User for PH and EP-A for Alkalinity	7.7	26.9			Yes
2/26/2026	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
2/27/2026	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
2/28/2026	1st User for PH and EP-A for Alkalinity	7.8				Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 3/9/2026