

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**


**PWS Name/ID:** Neskowin Reg Water Dist - 4100970  
**Sample Period (Month/Year):** March-21  
**Required Sample Frequency:** Ph Every Day  
**Required Sample Frequency:** Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
3/1/2021	1st User for PH and EP-A for Alkalinity	7.9	40			Yes
3/2/2021	1st User for PH and EP-A for Alkalinity	7.9	38			Yes
3/3/2021	1st User for PH and EP-A for Alkalinity	7.7	38			Yes
3/4/2021	1st User for PH and EP-A for Alkalinity	7.7	39			Yes
3/5/2021	1st User for PH and EP-A for Alkalinity	7.7	40			Yes
3/6/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
3/7/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
3/8/2021	1st User for PH and EP-A for Alkalinity	7.8	42			Yes
3/9/2021	1st User for PH and EP-A for Alkalinity	7.8	40			Yes
3/10/2021	1st User for PH and EP-A for Alkalinity	7.7	40			Yes
3/11/2021	1st User for PH and EP-A for Alkalinity	7.8	39			Yes
3/12/2021	1st User for PH and EP-A for Alkalinity	7.8	40			Yes
3/13/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
3/14/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes
3/15/2021	1st User for PH and EP-A for Alkalinity	7.7	38			Yes
3/16/2021	1st User for PH and EP-A for Alkalinity	7.8	39			Yes
3/17/2021	1st User for PH and EP-A for Alkalinity	7.8	41			Yes
3/18/2021	1st User for PH and EP-A for Alkalinity	7.7	40			Yes
3/19/2021	1st User for PH and EP-A for Alkalinity	7.7	40			Yes
3/20/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
3/21/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
3/22/2021	1st User for PH and EP-A for Alkalinity	7.7	42			Yes
3/23/2021	1st User for PH and EP-A for Alkalinity	7.7	44			Yes
3/24/2021	1st User for PH and EP-A for Alkalinity	7.7	42			Yes
3/25/2021	1st User for PH and EP-A for Alkalinity	7.8	43			Yes
3/26/2021	1st User for PH and EP-A for Alkalinity	7.7	40			Yes
3/27/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
3/28/2021	1st User for PH and EP-A for Alkalinity	7.4				Yes
3/29/2021	1st User for PH and EP-A for Alkalinity	7.6	39			Yes
3/30/2021	1st User for PH and EP-A for Alkalinity	7.6	38			Yes
3/31/2021	1st User for PH and EP-A for Alkalinity	7.6	39			Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 4/7/2021