

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**


**PWS Name/ID:** Neskowin Reg Water Dist - 4100970  
**Sample Period (Month/Year):** September-21  
**Required Sample Frequency:** Ph Every Day  
**Required Sample Frequency:** Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
9/1/2021	1st User for PH and EP-A for Alkalinity	7.6	27.0			Yes
9/2/2021	1st User for PH and EP-A for Alkalinity	7.6	27.5			Yes
9/3/2021	1st User for PH and EP-A for Alkalinity	7.6	26.8			Yes
9/4/2021	1st User for PH and EP-A for Alkalinity	8.0				Yes
9/5/2021	1st User for PH and EP-A for Alkalinity	8.0	28.2			Yes
9/6/2021	1st User for PH and EP-A for Alkalinity	8.1	28.0			Yes
9/7/2021	1st User for PH and EP-A for Alkalinity	8.1	27.3			Yes
9/8/2021	1st User for PH and EP-A for Alkalinity	8.1	27.0			Yes
9/9/2021	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
9/10/2021	1st User for PH and EP-A for Alkalinity	8.0				Yes
9/11/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes
9/12/2021	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
9/13/2021	1st User for PH and EP-A for Alkalinity	7.7	25.6			Yes
9/14/2021	1st User for PH and EP-A for Alkalinity	7.9	25.0			Yes
9/15/2021	1st User for PH and EP-A for Alkalinity	7.7	25.2			Yes
9/16/2021	1st User for PH and EP-A for Alkalinity	8.0	27.0			Yes
9/17/2021	1st User for PH and EP-A for Alkalinity	7.9				Yes
9/18/2021	1st User for PH and EP-A for Alkalinity	7.9	28.0			Yes
9/19/2021	1st User for PH and EP-A for Alkalinity	7.8	27.4			Yes
9/20/2021	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
9/21/2021	1st User for PH and EP-A for Alkalinity	7.2	27.4			Yes
9/22/2021	1st User for PH and EP-A for Alkalinity	7.3	28.0			Yes
9/23/2021	1st User for PH and EP-A for Alkalinity	7.2				Yes
9/24/2021	1st User for PH and EP-A for Alkalinity	7.2	25.2			Yes
9/25/2021	1st User for PH and EP-A for Alkalinity	7.9	25.3			Yes
9/26/2021	1st User for PH and EP-A for Alkalinity	7.7	26.5			Yes
9/27/2021	1st User for PH and EP-A for Alkalinity	7.2	26.7			Yes
9/28/2021	1st User for PH and EP-A for Alkalinity	7.2	25.4			Yes
9/29/2021	1st User for PH and EP-A for Alkalinity	7.3				Yes
9/30/2021	1st User for PH and EP-A for Alkalinity	7.3				Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 10/5/2021