

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): February-22
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
2/1/2022	1st User for PH and EP-A for Alkalinity	8.0	35.0			Yes
2/2/2022	1st User for PH and EP-A for Alkalinity	7.6	34.2			Yes
2/3/2022	1st User for PH and EP-A for Alkalinity	7.7	34.0			Yes
2/4/2022	1st User for PH and EP-A for Alkalinity	7.6	34.1			Yes
2/5/2022	1st User for PH and EP-A for Alkalinity	8.1				Yes
2/6/2022	1st User for PH and EP-A for Alkalinity	8.3				Yes
2/7/2022	1st User for PH and EP-A for Alkalinity	7.5	31.8			Yes
2/8/2022	1st User for PH and EP-A for Alkalinity	8.0	35.0			Yes
2/9/2022	1st User for PH and EP-A for Alkalinity	7.5	34.6			Yes
2/10/2022	1st User for PH and EP-A for Alkalinity	7.6	33.0			Yes
2/11/2022	1st User for PH and EP-A for Alkalinity	8.1	33.2			Yes
2/12/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/13/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/14/2022	1st User for PH and EP-A for Alkalinity	7.8	30.5			Yes
2/15/2022	1st User for PH and EP-A for Alkalinity	8.1	33.0			Yes
2/16/2022	1st User for PH and EP-A for Alkalinity	7.9	32.5			Yes
2/17/2022	1st User for PH and EP-A for Alkalinity	7.8	34.0			Yes
2/18/2022	1st User for PH and EP-A for Alkalinity	7.8	33.2			Yes
2/19/2022	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/20/2022	1st User for PH and EP-A for Alkalinity	8.1				Yes
2/21/2022	1st User for PH and EP-A for Alkalinity	8.1	35.0			Yes
2/22/2022	1st User for PH and EP-A for Alkalinity	8.0	34.8			Yes
2/23/2022	1st User for PH and EP-A for Alkalinity	8.1	34.6			Yes
2/24/2022	1st User for PH and EP-A for Alkalinity	7.7	32.0			Yes
2/25/2022	1st User for PH and EP-A for Alkalinity	7.8	34.6			Yes
2/26/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
2/27/2022	1st User for PH and EP-A for Alkalinity	7.6				Yes
2/28/2022	1st User for PH and EP-A for Alkalinity	7.5	34.2			Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 3/3/2022