

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): May-22
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
5/1/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/2/2022	1st User for PH and EP-A for Alkalinity	8.0	28.5			Yes
5/3/2022	1st User for PH and EP-A for Alkalinity	7.7	28.0			Yes
5/4/2022	1st User for PH and EP-A for Alkalinity	7.4	28.0			Yes
5/5/2022	1st User for PH and EP-A for Alkalinity	7.9	27.7			Yes
5/6/2022	1st User for PH and EP-A for Alkalinity	7.3	29.0			Yes
5/7/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/8/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/9/2022	1st User for PH and EP-A for Alkalinity	7.6	26.0			Yes
5/10/2022	1st User for PH and EP-A for Alkalinity	7.6	26.6			Yes
5/11/2022	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
5/12/2022	1st User for PH and EP-A for Alkalinity	7.9	25.7			Yes
5/13/2022	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
5/14/2022	1st User for PH and EP-A for Alkalinity	7.4				Yes
5/15/2022	1st User for PH and EP-A for Alkalinity	7.6				Yes
5/16/2022	1st User for PH and EP-A for Alkalinity	7.7	24.9			Yes
5/17/2022	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
5/18/2022	1st User for PH and EP-A for Alkalinity	7.4	26.5			Yes
5/19/2022	1st User for PH and EP-A for Alkalinity	7.4	25.5			Yes
5/20/2022	1st User for PH and EP-A for Alkalinity	7.7	25.9			Yes
5/21/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/22/2022	1st User for PH and EP-A for Alkalinity	7.9				Yes
5/23/2022	1st User for PH and EP-A for Alkalinity	7.5	26.6			Yes
5/24/2022	1st User for PH and EP-A for Alkalinity	7.3	26.0			Yes
5/25/2022	1st User for PH and EP-A for Alkalinity	7.7	25.6			Yes
5/26/2022	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
5/27/2022	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
5/28/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/29/2022	1st User for PH and EP-A for Alkalinity	7.9				Yes
5/30/2022	1st User for PH and EP-A for Alkalinity	7.9	25.0			Yes
5/31/2022	1st User for PH and EP-A for Alkalinity	7.7	25.2			Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 6/6/2022