

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): June-22

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month

| Day | Sample Location | pH | Alk | PO4 | Other | yes/no |
|-----------|---|-----|------|-----|-------|--------|
| 6/1/2022 | 1st User for PH and EP-A for Alkalinity | 7.3 | 24.5 | | | Yes |
| 6/2/2022 | 1st User for PH and EP-A for Alkalinity | 7.4 | 24.0 | | | Yes |
| 6/3/2022 | 1st User for PH and EP-A for Alkalinity | 7.3 | 24.6 | | | Yes |
| 6/4/2022 | 1st User for PH and EP-A for Alkalinity | 7.5 | | | | Yes |
| 6/5/2022 | 1st User for PH and EP-A for Alkalinity | 7.5 | | | | Yes |
| 6/6/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | 25.0 | | | Yes |
| 6/7/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | 24.6 | | | Yes |
| 6/8/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | 24.3 | | | Yes |
| 6/9/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | 24.3 | | | Yes |
| 6/10/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | 24.6 | | | Yes |
| 6/11/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | | | | Yes |
| 6/12/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | | | | Yes |
| 6/13/2022 | 1st User for PH and EP-A for Alkalinity | 7.6 | 25.0 | | | Yes |
| 6/14/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | 24.3 | | | Yes |
| 6/15/2022 | 1st User for PH and EP-A for Alkalinity | 7.7 | 24.3 | | | Yes |
| 6/16/2022 | 1st User for PH and EP-A for Alkalinity | 7.6 | 24.5 | | | Yes |
| 6/17/2022 | 1st User for PH and EP-A for Alkalinity | 7.6 | 24.3 | | | Yes |
| 6/18/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | | | | Yes |
| 6/19/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | | | | Yes |
| 6/20/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | 25.1 | | | Yes |
| 6/21/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | 25.0 | | | Yes |
| 6/22/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | 24.5 | | | Yes |
| 6/23/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | 24.6 | | | Yes |
| 6/24/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | 24.0 | | | Yes |
| 6/25/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | | | | Yes |
| 6/26/2022 | 1st User for PH and EP-A for Alkalinity | 8.0 | | | | Yes |
| 6/27/2022 | 1st User for PH and EP-A for Alkalinity | 8.1 | 24.0 | | | Yes |
| 6/28/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | 24.2 | | | Yes |
| 6/29/2022 | 1st User for PH and EP-A for Alkalinity | 7.8 | 24.2 | | | Yes |
| 6/30/2022 | 1st User for PH and EP-A for Alkalinity | 8.2 | 24.6 | | | Yes |
| | | | | | | |

| | |
|---|---|
| Total number of excursions for PH during this monitoring period = | 0 |
| Total number of excursions for Alkalinity during this monitoring period = | 0 |

Send to dvp.dmce@state.or.us within 10 days after end of sampling period

| | |
|---|-----|
| For OHA use only: | |
| Minimum Water Quality Parameters as set by: DHS | |
| pH | 7.2 |
| Alk | 23 |

Signature: 
 Print Name: Troy N. Trute
 Date: 7/7/2022