

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): August-22

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
8/1/2022	1st User for PH and EP-A for Alkalinity	7.8	24.2			Yes
8/2/2022	1st User for PH and EP-A for Alkalinity	7.8	24.0			Yes
8/3/2022	1st User for PH and EP-A for Alkalinity	7.8	23.9			Yes
8/4/2022	1st User for PH and EP-A for Alkalinity	7.8	24.2			Yes
8/5/2022	1st User for PH and EP-A for Alkalinity	7.8	24.5			Yes
8/6/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/7/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/8/2022	1st User for PH and EP-A for Alkalinity	7.8	24.6			Yes
8/9/2022	1st User for PH and EP-A for Alkalinity	7.8	24.0			Yes
8/10/2022	1st User for PH and EP-A for Alkalinity	7.8	24.5			Yes
8/11/2022	1st User for PH and EP-A for Alkalinity	7.9	24.0			Yes
8/12/2022	1st User for PH and EP-A for Alkalinity	7.8	23.8			Yes
8/13/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/14/2022	1st User for PH and EP-A for Alkalinity	7.9				Yes
8/15/2022	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
8/16/2022	1st User for PH and EP-A for Alkalinity	7.8	24.5			Yes
8/17/2022	1st User for PH and EP-A for Alkalinity	7.9	24.8			Yes
8/18/2022	1st User for PH and EP-A for Alkalinity	7.9	24.0			Yes
8/19/2022	1st User for PH and EP-A for Alkalinity	7.8	24.8			Yes
8/20/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/21/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/22/2022	1st User for PH and EP-A for Alkalinity	7.8	23.7			Yes
8/23/2022	1st User for PH and EP-A for Alkalinity	7.8	24.5			Yes
8/24/2022	1st User for PH and EP-A for Alkalinity	7.8	24.7			Yes
8/25/2022	1st User for PH and EP-A for Alkalinity	7.8	24.7			Yes
8/26/2022	1st User for PH and EP-A for Alkalinity	7.8	23.7			Yes
8/27/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/28/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/29/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/30/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/31/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes

Total number of excursions for PH during this monitoring period = 0

Total number of excursions for Alkalinity during this monitoring period = 0


Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:

Print Name:

Date:



 Troy N. Trute

 9/1/2022
