

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): September-22

Required Sample Frequency: Ph Every Day


Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
9/1/2022	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
9/2/2022	1st User for PH and EP-A for Alkalinity	7.8	24.6			Yes
9/3/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/4/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/5/2022	1st User for PH and EP-A for Alkalinity	7.8	26.2			Yes
9/6/2022	1st User for PH and EP-A for Alkalinity	7.8	25.3			Yes
9/7/2022	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
9/8/2022	1st User for PH and EP-A for Alkalinity	7.8	24.6			Yes
9/9/2022	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
9/10/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/11/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/12/2022	1st User for PH and EP-A for Alkalinity	8.0	24.1			Yes
9/13/2022	1st User for PH and EP-A for Alkalinity	7.9	27.2			Yes
9/14/2022	1st User for PH and EP-A for Alkalinity	7.9	27.0			Yes
9/15/2022	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
9/16/2022	1st User for PH and EP-A for Alkalinity	7.7	26.5			Yes
9/17/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/18/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
9/19/2022	1st User for PH and EP-A for Alkalinity	7.7	25.3			Yes
9/20/2022	1st User for PH and EP-A for Alkalinity	7.8	24.5			Yes
9/21/2022	1st User for PH and EP-A for Alkalinity	7.8	24.8			Yes
9/22/2022	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
9/23/2022	1st User for PH and EP-A for Alkalinity	7.7	25.3			Yes
9/24/2022	1st User for PH and EP-A for Alkalinity	7.6				Yes
9/25/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
9/26/2022	1st User for PH and EP-A for Alkalinity	7.7	25.6			Yes
9/27/2022	1st User for PH and EP-A for Alkalinity	7.8	28.0			Yes
9/28/2022	1st User for PH and EP-A for Alkalinity	7.8	28.2			Yes
9/29/2022	1st User for PH and EP-A for Alkalinity	7.7	27.5			Yes
9/30/2022	1st User for PH and EP-A for Alkalinity	7.8	26.2			Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 10/3/2022