

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): November-22

Required Sample Frequency: Ph Every Day


Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
11/1/2022	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
11/2/2022	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
11/3/2022	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
11/4/2022	1st User for PH and EP-A for Alkalinity	7.5	24.9			Yes
11/5/2022	1st User for PH and EP-A for Alkalinity	7.5				Yes
11/6/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/7/2022	1st User for PH and EP-A for Alkalinity	7.5	25.5			Yes
11/8/2022	1st User for PH and EP-A for Alkalinity	7.5	26.0			Yes
11/9/2022	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
11/10/2022	1st User for PH and EP-A for Alkalinity	7.7	25.2			Yes
11/11/2022	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
11/12/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/13/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/14/2022	1st User for PH and EP-A for Alkalinity	7.7	26.2			Yes
11/15/2022	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
11/16/2022	1st User for PH and EP-A for Alkalinity	7.7	25.7			Yes
11/17/2022	1st User for PH and EP-A for Alkalinity	7.7	25.8			Yes
11/18/2022	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
11/19/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/20/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/21/2022	1st User for PH and EP-A for Alkalinity	7.7	26.3			Yes
11/22/2022	1st User for PH and EP-A for Alkalinity	7.7	25.6			Yes
11/23/2022	1st User for PH and EP-A for Alkalinity	7.7	25.5			Yes
11/24/2022	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
11/25/2022	1st User for PH and EP-A for Alkalinity	7.7	26.1			Yes
11/26/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/27/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
11/28/2022	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
11/29/2022	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
11/30/2022	1st User for PH and EP-A for Alkalinity	7.9	26.4			Yes

Total number of excursions for PH during this monitoring period =	0
Total number of excursions for Alkalinity during this monitoring period =	0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 12/1/2022