

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): January-23
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
1/1/2023	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/2/2023	1st User for PH and EP-A for Alkalinity	7.7	26.2			Yes
1/3/2023	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
1/4/2023	1st User for PH and EP-A for Alkalinity	7.7	25.3			Yes
1/5/2023	1st User for PH and EP-A for Alkalinity	7.6	25.6			Yes
1/6/2023	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
1/7/2023	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/8/2023	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/9/2023	1st User for PH and EP-A for Alkalinity	7.6	26.0			Yes
1/10/2023	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
1/11/2023	1st User for PH and EP-A for Alkalinity	7.7	25.2			Yes
1/12/2023	1st User for PH and EP-A for Alkalinity	7.7	25.5			Yes
1/13/2023	1st User for PH and EP-A for Alkalinity	7.7	25.4			Yes
1/14/2023	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/15/2023	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/16/2023	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
1/17/2023	1st User for PH and EP-A for Alkalinity	7.7	24.8			Yes
1/18/2023	1st User for PH and EP-A for Alkalinity	7.8	24.9			Yes
1/19/2023	1st User for PH and EP-A for Alkalinity	7.8	25.3			Yes
1/20/2023	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
1/21/2023	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/22/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/23/2023	1st User for PH and EP-A for Alkalinity	7.8	25.2			Yes
1/24/2023	1st User for PH and EP-A for Alkalinity	7.9	24.6			Yes
1/25/2023	1st User for PH and EP-A for Alkalinity	8.0	24.6			Yes
1/26/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
1/27/2023	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
1/28/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
1/29/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
1/30/2023	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
1/31/2023	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dvp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 2/9/2023