

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): February-23

Required Sample Frequency: Ph Every Day


Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
2/1/2023	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
2/2/2023	1st User for PH and EP-A for Alkalinity	8.0	25.7			Yes
2/3/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
2/4/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/5/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/6/2023	1st User for PH and EP-A for Alkalinity	8.0	36.3			Yes
2/7/2023	1st User for PH and EP-A for Alkalinity	8.0	36.0			Yes
2/8/2023	1st User for PH and EP-A for Alkalinity	7.8	35.8			Yes
2/9/2023	1st User for PH and EP-A for Alkalinity	8.0	36.0			Yes
2/10/2023	1st User for PH and EP-A for Alkalinity	7.8	36.3			Yes
2/11/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/12/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/13/2023	1st User for PH and EP-A for Alkalinity	7.9	25.8			Yes
2/14/2023	1st User for PH and EP-A for Alkalinity	7.9	26.8			Yes
2/15/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
2/16/2023	1st User for PH and EP-A for Alkalinity	7.8	25.6			Yes
2/17/2023	1st User for PH and EP-A for Alkalinity	7.9	26.3			Yes
2/18/2023	1st User for PH and EP-A for Alkalinity	7.9				Yes
2/19/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/20/2023	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
2/21/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
2/22/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
2/23/2023	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
2/24/2023	1st User for PH and EP-A for Alkalinity	7.8	26.7			Yes
2/25/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/26/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/27/2023	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
2/28/2023	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 3/2/2023