

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**


**PWS Name/ID:** Neskowin Reg Water Dist - 4100970  
**Sample Period (Month/Year):** March-23  
**Required Sample Frequency:** Ph Every Day  
**Required Sample Frequency:** Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
3/1/2023	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
3/2/2023	1st User for PH and EP-A for Alkalinity	8.1	26.4			Yes
3/3/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
3/4/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/5/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/6/2023	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
3/7/2023	1st User for PH and EP-A for Alkalinity	8.0	25.6			Yes
3/8/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
3/9/2023	1st User for PH and EP-A for Alkalinity	7.9	25.3			Yes
3/10/2023	1st User for PH and EP-A for Alkalinity	7.9	26.0			Yes
3/11/2023	1st User for PH and EP-A for Alkalinity	7.9				Yes
3/12/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
3/13/2023	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
3/14/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
3/15/2023	1st User for PH and EP-A for Alkalinity	7.9	26.3			Yes
3/16/2023	1st User for PH and EP-A for Alkalinity	7.9	26.3			Yes
3/17/2023	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
3/18/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/19/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/20/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
3/21/2023	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
3/22/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
3/23/2023	1st User for PH and EP-A for Alkalinity	8.0	25.6			Yes
3/24/2023	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
3/25/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/26/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/27/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
3/28/2023	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
3/29/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
3/30/2023	1st User for PH and EP-A for Alkalinity	8.0	26.6			Yes
3/31/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 4/3/2023