

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): April-23

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month


Day	Sample Location	pH	Alk	PO4	Other	yes/no
4/1/2023	1st User for PH and EP-A for Alkalinity	8.1				Yes
4/2/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
4/3/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
4/4/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
4/5/2023	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
4/6/2023	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
4/7/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
4/8/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
4/9/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
4/10/2023	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
4/11/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
4/12/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
4/13/2023	1st User for PH and EP-A for Alkalinity	8.0	25.3			Yes
4/14/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
4/15/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
4/16/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
4/17/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
4/18/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
4/19/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
4/20/2023	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
4/21/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
4/22/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
4/23/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
4/24/2023	1st User for PH and EP-A for Alkalinity	8.0	26.7			Yes
4/25/2023	1st User for PH and EP-A for Alkalinity	8.0	27.0			Yes
4/26/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
4/27/2023	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
4/28/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
4/29/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
4/30/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes

Total number of excursions for PH during this monitoring period = 0

Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 

Print Name: Troy N. Trute

Date: 5/9/2023