

OREGON HEALTH
AUTHORITY

Lead & Copper Rule Corrosion Control

Day	Ph	Alk	Phos	Sili	Y/N	<< Have Minimums Been Met for this day
1	7.5				Y	
2	7.5				Y	
3	7.5				Y	
4	7.5				Y	
5	7.5				Y	
6	7.5				Y	
7	7.6				Y	
8	7.6				Y	
9	7.6				Y	
10	7.5				Y	
11	7.5				Y	
12	7.5				Y	
13	7.6				Y	
14	7.6				Y	
15	7.4				Y	
16	7.5				Y	
17	7.5				Y	
18	7.5				Y	
19	7.6				Y	
20	7.6				Y	
21	7.5				Y	
22	7.4				Y	
23	7.4				Y	
24	7.5				Y	
25	7.6				Y	
26	7.5				Y	
27	7.5				Y	
28	7.6				Y	
29	7.6				Y	
30	7.4				Y	
31	7.5				Y	
No = N = Excursion					Total N's	0

County: Josephine Agency: 5 Entry Point A PWS ID 4100971 Cave Junction, City of Sample Period: Month/Year Aug. 2024
--

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference Minimum Water Quality Parameter(s) as set by State: pH 7.3

Print Name: Steven Bethke
 Signature: Steven Bethke
 Date: 9-4-24

Send to DWP within 10 days after end of sampling period
 DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp