

OREGON HEALTH
AUTHORITY

Lead & Copper Rule Corrosion Control

Day	Ph	Alk	Phos	Sili	Y/N	<< Have Minimums Been Met for this day
1						
2	7.6				Y	
3						
4	7.6				Y	
5						
6	7.6				Y	
7						
8						
9	7.6				Y	
10						
11	7.6				Y	
12						
13	7.7				Y	
14						
15						
16						
17	7.5				Y	
18	7.6				Y	
19						
20	7.4				Y	
21						
22						
23	7.6				Y	
24						
25						
26						
27	7.5				Y	
28						
29						
30	7.6				Y	
31						
No = N = Excursion					Total N's	0

County: Josephine Agency: 5

Entry Point
A
PWS ID 4100971
Cave Junction, City of

Sample Period:
Month/Year Dec. 2024

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3

Print Name: Steven Bethke
Signature: Steven Bethke
Date: 1-6-25

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp