

OREGON HEALTH

AUTHORITY

## Lead &amp; Copper Rule Corrosion Control

Day	Ph	Alk	Phos	Sili	Y/N	<< Have Minimums Been Met for this day
1	7.5				Y	
2						
3	7.5				Y	
4						
5	7.5				Y	
6						
7						
8	7.4				Y	
9						
10						
11						
12	7.4				Y	
13						
14						
15	7.5				Y	
16	7.5				Y	
17						
18	7.5				Y	
19						
20						
21						
22						
23	7.5				Y	
24						
25						
26	7.5				Y	
27						
28						
29	7.5				Y	
30						
31						

No = N = Excursion      Total N's      0

County: Josephine	Agency: 5
Entry Point	
A	
PWS ID 4100971	
Cave Junction, City of	
Sample Period:	
Month/Year Dec. 2025	

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference	
Minimum Water Quality	
Parameter(s) as set by State:	
pH	7.3

Print Name: Steven Betheke  
 Signature: Steven Betheke  
 Date: 1-5-26

Send to DWP within 10 days after end of sampling period  
 DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone: (503) 731-4381   Website: [www.ohd.hr.state.or.us/dwp](http://www.ohd.hr.state.or.us/dwp)