

OREGON HEALTH
AUTHORITY

Lead & Copper Rule Corrosion Control

| Day | Ph | Alk | Phos | Sili | Y/N | << Have Minimums Been Met for this day |
|--------------------|-----|-----|------|------|------------------|---|
| 1 | | | | | | |
| 2 | | | | | | |
| 3 | 7.7 | | | | Y | |
| 4 | | | | | | |
| 5 | 7.4 | | | | Y | |
| 6 | | | | | | |
| 7 | | | | | | |
| 8 | | | | | | |
| 9 | | | | | | |
| 10 | 7.5 | | | | Y | |
| 11 | | | | | | |
| 12 | 7.4 | | | | Y | |
| 13 | 7.4 | | | | Y | |
| 14 | | | | | | |
| 15 | | | | | | |
| 16 | | | | | | |
| 17 | | | | | | |
| 18 | 7.4 | | | | Y | |
| 19 | | | | | | |
| 20 | 7.4 | | | | Y | |
| 21 | | | | | | |
| 22 | | | | | | |
| 23 | | | | | | |
| 24 | | | | | | |
| 25 | 7.4 | | | | Y | |
| 26 | 7.4 | | | | Y | |
| 27 | | | | | | |
| 28 | | | | | | |
| 29 | | | | | | |
| 30 | | | | | | |
| 31 | | | | | | |
| No = N = Excursion | | | | | Total N's | 0 |

County: Josephine Agency: 5

Entry Point
A
PWS ID 4100971
Cave Junction, City of

Sample Period:
Month/Year Feb. 2026

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3

Print Name: Steven Bethke
Signature: *Steven Bethke*
Date: 3-3-26

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp