

OREGON HEALTH  
AUTHORITY

### Lead & Copper Rule Corrosion Control

Day	Ph	Alk	Phos	Sili	Y/N	<< Have Minimums Been Met for this day
1						
2	7.5				Y	
3						
4	7.4				Y	
5						
6	7.4				Y	
7						
8						
9						
10	7.4				Y	
11	7.4				Y	
12	7.4				Y	
13						
14						
15						
16	7.5				Y	
17						
18	7.5				Y	
19						
20	7.5				Y	
21						
22						
23	7.5				Y	
24						
25	7.5				Y	
26						
27	7.6				Y	
28						
29						
30	7.5				Y	
31	7.5				Y	
No = N = Excursion					Total N's	0

County: Josephine Agency: 5

**Entry Point**  
**A**  
**PWS ID 4100971**  
**Cave Junction, City of**

Sample Period:  
Month/Year Mar. 2026

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion<sup>1</sup> is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.3

Print Name: Steven Bethke  
Signature: *Steven Bethke*  
Date: 4-9-26

Send to DWP within 10 days after end of sampling period  
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp