

AUTHORITY

Lead & Copper Rule Corrosion Control

Day	Ph	Alk	Phos	Sili	Y/N	<< Have Minimums Been Met for this day
1	7.3				Y	
2	7.3				Y	
3	7.4				Y	
4	7.3				Y	
5	7.5				Y	
6	7.4				Y	
7	7.4				Y	
8	7.4				Y	
9	7.5				Y	
10	7.5				Y	
11	7.5				Y	
12	7.2				N	
13	7.3				Y	
14	7.3				Y	
15	7.3				Y	
16	7.3				Y	
17	7.1				N	
18	7.2				N	
19	7.2				N	
20	7.3				Y	
21	7.3				Y	
22	7.3				Y	
23	7.4				Y	
24	7.6				Y	
25	7.5				Y	
26	7.4				Y	
27	7.3				Y	
28	7.4				Y	
29	7.3				Y	
30	7.3				Y	
31	0					
No = N = Excursion					Total N's	4

County: Josephine Agency: 5  
**Entry Point**  
**A**  
**PWS ID 4100971**  
**Cave Junction, City of**

Sample Period:  
 Month/Year Sept. 2021

Number of excursions during this month: 4

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
 Parameter(s) as set by State:**

pH 7.3

Print Name: Steven Bethke  
 Signature: Steven Bethke  
 Date: 10-5-21

Send to DWP within 10 days after end of sampling period  
 DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp