

Lead & Copper Rule Corrosion Control

AUTHORITY

Day	Ph	Alk	Phos	Sili	Y/N	<< Have Minimums Been Met for this day
1	7.5				Y	
2						
3	7.6				Y	
4						
5						
6						
7						
8	7.6				Y	
9	7.4				Y	
10						
11	7.4				Y	
12						
13						
14	7.4				Y	
15						
16						
17	7.4				Y	
18						
19						
20						
21	7.3				Y	
22	7.5				Y	
23						
24	7.4				Y	
25	7.6				Y	
26						
27						
28	7.4				Y	
29						
30	7.5				Y	
31						
No = N = Excursion					Total N's	0

County: Josephine Agency: 5

Entry Point
A
PWS ID 4100971
Cave Junction, City of

Sample Period:
Month/Year Mar 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3

Print Name: Steven Bethke
Signature: *Steven Bethke*
Date: 4-11-22

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp