

AUTHORITY

Lead & Copper Rule Corrosion Control

Day	Ph	Alk	Phos	Sili	Y/N	<< Have Minimums Been Met for this day
1	7.3				Y	
2	7.6				Y	
3	7.5				Y	
4	7.6				Y	
5	7.4				Y	
6	7.4				Y	
7	7.5				Y	
8	7.4				Y	
9	7.5				Y	
10	7.6				Y	
11	7.5				Y	
12	7.6				Y	
13	7.4				Y	
14	7.5				Y	
15	7.5				Y	
16	7.3				Y	
17	7.2				N	
18	7.4				Y	
19	7.5				Y	
20	7.5				Y	
21	7.4				Y	
22	7.5				Y	
23	7.4				Y	
24	7.4				Y	
25	7.3				Y	
26	7.4				Y	
27	7.4				Y	
28	7.4				Y	
29	7.3				Y	
30	7.3				Y	
31	7.3				Y	
No = N = Excursion					<b>Total N's</b>	1

County: Josephine Agency: 5

**Entry Point**  
A

**PWS ID 4100971**  
Cave Junction, City of

Sample Period:  
Month/Year July, 2022

Number of excursions during this month: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.3

Print Name: Steven Bethke  
Signature: Steven Bethke  
Date: 8-3-22

Send to DWP within 10 days after end of sampling period  
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp