

OREGON HEALTH
AUTHORITY

Lead & Copper Rule Corrosion Control

Day	Ph	Alk	Phos	Sili	Y/N	<< Have Minimums Been Met for this day
1	7.5				Y	
2						
3	7.5				Y	
4						
5						
6	7.6				Y	
7						
8						
9	7.5				Y	
10	7.4				Y	
11						
12						
13	7.5				Y	
14	7.5				Y	
15	7.5				Y	
16	7.4				Y	
17	7.4				Y	
18						
19	7.3				Y	
20	7.7				Y	
21	7.7				Y	
22	7.7				Y	
23	7.7				Y	
24	7.6				Y	
25						
26	7.6				Y	
27						
28	7.6				Y	
29	7.4				Y	
30	7.5				Y	
31	7.5				Y	
No = N = Excursion					Total N's	0

County: Josephine Agency: 5

Entry Point
A
PWS ID 4100971
Cave Junction, City of

Sample Period:
Month/Year May, 2024

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.3

Print Name: Steven Bethke
Signature: Steven Bethke
Date: 6-4-24

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp