

OREGON HEALTH
AUTHORITY

Lead & Copper Rule Corrosion Control

| Day | Ph | Alk | Phos | Sili | Y/N | << Have Minimums Been Met for this day |
|--------------------|-----|-----|------|------|-----------|---|
| 1 | | | | | | |
| 2 | | | | | | |
| 3 | | | | | | |
| 4 | 7.4 | | | | Y | |
| 5 | 7.5 | | | | Y | |
| 6 | 7.5 | | | | Y | |
| 7 | 7.5 | | | | Y | |
| 8 | 7.5 | | | | Y | |
| 9 | | | | | | |
| 10 | | | | | | |
| 11 | | | | | | |
| 12 | 7.6 | | | | Y | |
| 13 | 7.6 | | | | Y | |
| 14 | | | | | | |
| 15 | | | | | | |
| 16 | 7.5 | | | | Y | |
| 17 | | | | | | |
| 18 | 7.4 | | | | Y | |
| 19 | 7.4 | | | | Y | |
| 20 | | | | | | |
| 21 | 7.7 | | | | Y | |
| 22 | | | | | | |
| 23 | | | | | | |
| 24 | | | | | | |
| 25 | 7.7 | | | | Y | |
| 26 | 7.6 | | | | Y | |
| 27 | 7.6 | | | | Y | |
| 28 | | | | | | |
| 29 | | | | | | |
| 30 | | | | | | |
| 31 | | | | | | |
| No = N = Excursion | | | | | Total N's | 0 |

| |
|--|
| County: Josephine Agency: 5 Entry Point A PWS ID 4100971 Cave Junction, City of Sample Period: Month/Year Nov. 2024 |
|--|

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

| |
|---|
| Reference Minimum Water Quality Parameter(s) as set by State: pH 7.3 |
|---|

Print Name: Steven Bethke
 Signature: *Steven Bethke*
 Date: 12-3-24

Send to DWP within 10 days after end of sampling period
 DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone: (503) 731-4381 Website: www.ohd.hr.state.or.us/dwp