

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3		↑			
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21	7.04		1.1		
22	7.09		1.2		
23	7.06		1.6		
24	7.03		1.3		
25	7.12		1.7		
26	7.39		1.8		
27	7.47		2.2		
28	X		X		
29	7.34		2.6		
30	7.43		2.5		
31	7.41		2.4		
(No = N = Excursion) Total N's					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	9	7	7
---	---	---	---	---

System Name: Jackson Creek Water Assoc.

Entry Point: pumphouse #1

Sample Period: August 2025

Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Toby Westberry

Signature: 

Date: 9/1/2025

Send to DWP within 10 days after end of sampling period