

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.16		1.5		
3					
4					
5					
6	7.25		1.4		
7					
8	7.19		1.4		
9					
10					
11					
12					
13					
14					
15	7.27		1.6		
16					
17					
18					
19					
20	7.15		1.6		
21					
22					
23					
24					
25					
26					
27					
28	7.20		1.5		
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	9	7	7
---	---	---	---	---

System Name: Jackson Creek Water Assoc.

Entry Point: pumphouse #1

Sample Period: March 2026
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="checkbox"/>	
Alk	<input type="checkbox"/>	(Alkalinity)
PO4	<input type="checkbox"/>	(Orthophosphate)
Other	<input type="checkbox"/>	(_____)

Print Name: Toby Westberry

Signature: 

Date: 04/06/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>