

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2					Y
3					Y
4					Y
5					Y
6					Y
7					Y
8					Y
9					Y
10					Y
11					Y
12					Y
13	7.6				Y
14					Y
15					Y
16					Y
17					Y
18					Y
19					Y
20					Y
21	7.8				Y
22					Y
23					Y
24					Y
25					Y
26					Y
27					Y
28					Y
29					Y
30					Y
31	7.6				Y

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID:** 41

**System Name:** GRANDVIEW MHP

**Entry Point:** EP-A

**Sample Period:** October 2021  
*Month/Year*

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

**Print Name:** DAN REITZ

**Signature:**

**Date:** 11/04/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**