Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3					Y
4					Y
5					Y
6					Y
7					Y
8	7.9				Y
9					Y
10					Y
11					Y
12					Y
13					Y
14					Y
15					Y
16					Y
17	7.8				Y
18					Y
19					Y
20					Y
21					Y
22					Y
23					Y
24	7.8				Y
25					Y
26					Y
27					Y
28					Y
29					Y
30	7.8				Y
31					Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 9 9 1

System Name: GRANDVIEW MHP

Entry Point: EP-A

Sample Period: November 2021

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		*(Alkalinity)*
PO4		*(Orthophosphate)*
Other		*(_____)*

Print Name: DAN REITZ

Signature:

Date: 12/03/2021

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/