

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3	8.1				Y
4					Y
5					Y
6					Y
7					Y
8	8.2				Y
9	8.0				Y
10					Y
11					Y
12					Y
13					Y
14	8.1				Y
15					Y
16	8.1				Y
17					Y
18					Y
19					Y
20					Y
21					Y
22					Y
23					Y
24	8.2				Y
25					Y
26					Y
27	8.0				Y
28					Y
29					Y
30					Y
31					Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: GRANDVIEW MHP

Entry Point: EP-A

Sample Period: April 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: DAN REITZ

Signature:

Date: 05/09/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's