

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2					Y
3					Y
4					Y
5					Y
6	7.6				Y
7					Y
8					Y
9	7.6				Y
10					Y
11					Y
12					Y
13	7.6				Y
14					Y
15	7.6				Y
16					Y
17					Y
18	7.5				Y
19					Y
20					Y
21					Y
22	7.6				Y
23					Y
24					Y
25					Y
26	7.4				Y
27					Y
28					Y
29	7.4				Y
30					Y
31					Y

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID:** 41

**System Name:** GRANDVIEW MHP

**Entry Point:** EP-A

**Sample Period:** May 2023  
*Month/Year*

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

**Print Name:** DAN REITZ

**Signature:**

**Date:** 06/06/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**