

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2					Y
3					Y
4					Y
5					Y
6					Y
7	7.5				Y
8					Y
9					Y
10	7.4				Y
11					Y
12					Y
13	7.4				Y
14					Y
15					Y
16					Y
17	7.5				Y
18					Y
19					Y
20					Y
21					Y
22	7.6				Y
23					Y
24					Y
25					Y
26					Y
27					Y
28	7.6				Y
29					Y
30	7.7				Y
31					Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: GRANDVIEW MHP

Entry Point: EP-A

Sample Period: November 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk *(Alkalinity)*

PO4 *(Orthophosphate)*

Other *(_____)*

Print Name: DAN REITZ

Signature:

Date: 12/01/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**