

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2					Y
3					Y
4					Y
5					Y
6	7.6				Y
7					Y
8					Y
9					Y
10	7.6				Y
11					Y
12					Y
13					Y
14					Y
15	7.8				Y
16					Y
17					Y
18					Y
19	7.8				Y
20					Y
21					Y
22					Y
23					Y
24					Y
25					Y
26	7.8				Y
27					Y
28					Y
29					Y
30	7.7				Y
31					Y

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID:** 41

**System Name:** GRANDVIEW MHP

**Entry Point:** EP-A

**Sample Period:** December 2024  
*Month/Year*

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

**Print Name:** DAN REITZ

**Signature:**

**Date:** 01/06/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**