

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2	7.7				Y
3					Y
4					Y
5					Y
6					Y
7	7.7				Y
8					Y
9					Y
10					Y
11	7.7				Y
12					Y
13					Y
14	7.6				Y
15					Y
16					Y
17					Y
18					Y
19					Y
20	7.7				Y
21					Y
22					Y
23					Y
24					Y
25	7.7				Y
26					Y
27					Y
28	7.7				Y
29					Y
30					Y
31					Y

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00991

System Name: GRANDVIEW MHP

Entry Point: EP-A

Sample Period: FEBRUARY 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: DAN REITZ

Signature: _____

Date: 03/10/2025

Send to DWP within 10 days after end of sampling period