

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2	7.6				Y
3					Y
4					Y
5	7.6	71			Y
6					Y
7					Y
8					Y
9	7.6				Y
10					Y
11	7.7	72			Y
12					Y
13					Y
14	7.7				Y
15					Y
16	7.7				Y
17					Y
18					Y
19	7.7				Y
20					Y
21					Y
22					Y
23	7.7	74			Y
24					Y
25					Y
26					Y
27					Y
28					Y
29	7.6				Y
30					Y
31					Y

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 0||0||9||9||1

System Name: GRANDVIEW MHP

Entry Point: EP-A

Sample Period: NOVEMBER 2025

Month/Year

Number of excursions* during this month: 0

*(Count the number of days when any WQP was
less than the minimum required)*

Total excursions during the previous 5 months: 0

*(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)*

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>55</u>	(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: DAN REITZ

Signature: 

Date: 12/05/2025

Send to DWP within 10 days after end of
sampling period