

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3	7.2				Y
4					Y
5	7.2				Y
6					Y
7					Y
8					Y
9	7.2				Y
10					Y
11	7.2	80			Y
12					Y
13	7.2				Y
14					Y
15					Y
16	7.4				Y
17					Y
18					Y
19	7.3	80			Y
20					Y
21	7.4				Y
22					Y
23					Y
24	7.4				Y
25					Y
26					Y
27					Y
28	7.4	85			Y
29					Y
30					Y
31					Y

<<Have

minimums  
been met for  
this day?

## ENTRY POINT

**PWS ID: 41** | 0 | 0 | 9 | 9 | 1 |

**System Name:** GRANDVIEW MHP

**Entry Point:** EP-A

**Sample Period:** FEBRUARY 2026

*Month/Year*

**Number of excursions\* during this month:** 0

*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>55</u>	<i>(Alkalinity)</i>
PO4	<u></u>	<i>(Orthophosphate)</i>
Other	<u></u>	<i>(_____)</i>

**Print Name:** DAN REITZ

**Signature:**

**Date:** 03/02/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0