

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				Y
2					Y
3					Y
4	7.3				Y
5					Y
6	7.3				Y
7					Y
8					Y
9	7.4	84			Y
10					Y
11	7.2				Y
12					Y
13					Y
14					Y
15	7.3				Y
16					Y
17	7.3				Y
18					Y
19	7.3	88			Y
20					Y
21					Y
22	7.3				Y
23					Y
24					Y
25	7.3				Y
26					Y
27	7.3				Y
28					Y
29					Y
30	7.4				Y
31					Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 | 0 | 0 | 9 | 9 | 1 |

System Name: GRANDVIEW MHP

Entry Point: EP-A

Sample Period: MARCH 2026
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>55</u>	(Alkalinity)
PO4	<u></u>	(Orthophosphate)
Other	<u></u>	(_____)

Print Name: DAN REITZ

Signature:

Date: 04/01/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0