

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3					Y
4					Y
5	7.5				Y
6					Y
7					Y
8	7.9				Y
9					Y
10					Y
11					Y
12	7.9				Y
13					Y
14					Y
15					Y
16					Y
17	7.9				Y
18					Y
19					Y
20					Y
21					Y
22					Y
23					Y
24	7.7				Y
25					Y
26					Y
27					Y
28					Y
29					Y
30	8.0				Y
31					Y

(No = N = Excursion) **Total N's** 0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00991

System Name: GRANDVIEW MHP

Entry Point: EP-A

Sample Period: MAY 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: DAN REITZ

Signature: 

Date: 06/08/2021

Send to DWP within 10 days after end of sampling period