

Day	pH	Alk	Phos	Other	Y/N
1					Y
2					Y
3					Y
4	7.2				Y
5					Y
6	7.2				Y
7					Y
8					Y
9					Y
10					Y
11	7.2				Y
12					Y
13					Y
14					Y
15					Y
16	7.2				Y
17					Y
18					Y
19					Y
20					Y
21	7.3				Y
22					Y
23	7.3				Y
24					Y
25					Y
26	7.3				Y
27					Y
28					Y
29					Y
30	7.5				Y
31	7.4				Y

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 41**

**System Name:** GRANDVIEW MHP LLC

**Entry Point:** EP-A

**Sample Period:** OCTOBER 2022  
*Month/Year*

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

**Print Name:** DAN REITZ

**Signature:**

**Date:** 11/1/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**