

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0	40			Y
2					
3					
4	7.8	40			Y
5					
6	7.8	40			Y
7					
8	7.9	40			Y
9					
10	7.9	40			Y
11					
12					
13					
14	7.8	40			Y
15					
16					
17	8.2	45			Y
18					
19	8.0	45			Y
20	7.9	45			Y
21	7.9	40			Y
22	8.0	45			Y
23					
24					
25	7.8	35			Y
26					
27					
28	7.6	35			Y
29					
30					
31	7.8	40			Y

<<Have minimums been met for this day?

## ENTRY POINT

EP-A

PWS ID 4101072

Johnson Creek Water Service

Sample Period: January 2021  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

For OHA use only

### Minimum Water Quality Parameters as set by

pH 7.2  
Alk 30.0 (Alkalinity)

Print Name: Matt Olson

Signature: 

Date: 02-06-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0