

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.8	55			Y
4					
5					
6					
7	7.7	60			Y
8					
9					
10					
11					
12					
13					
14					
15					
16					
17	7.8	55			Y
18					
19					
20					
21	7.7	45			Y
22					
23					
24					
25					
26					
27					
28					
29	7.8	55			Y
30	7.8	50			Y
31					

<<Have minimums been met for this day?

ENTRY POINT
 EP-A
 PWS ID 4101072
 Johnson Creek Water Service

Sample Period: December 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk 30.0 *(Alkalinity)*

Print Name: Matt Olson
Signature: 
Date: 01-10-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0