

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	8.1	40			Y
5	8.2	45			Y
6					
7					
8					
9					
10					
11					
12					
13					
14	7.9	40			Y
15					
16	7.9	40			Y
17					
18					
19					
20	8.0	45			Y
21	8.0	45			Y
22					
23					
24	7.6	35			Y
25	7.9	30			Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

EP-A
PWS ID 4101072
Johnson Creek Water Service

Sample Period: February 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk 30.0 (Alkalinity)

Print Name: Matt Olson
Signature: *Matt Olson*
Date: 3-3-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0