

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.4	35			Y
6					
7					
8					
9	7.4	35			Y
10					
11					
12	7.9	40			Y
13					
14					
15	8.0	40			Y
16					
17					
18					
19	7.4	40			Y
20					
21					
22	7.5	40			Y
23					
24					
25					
26	7.9	35			Y
27					
28					
29	8.0	40			Y
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**  
 EP-A  
 PWS ID 4101072  
 Johnson Creek Water Service

Sample Period: May 2022  
*Month/Year*

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.2  
 Alk 30.0 (Alkalinity)

Print Name: Matt Olson  
 Signature: *Matt Olson*  
 Date: 6-8-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0