

# Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
2		7.9	55			Y
3		7.7	50			Y
5		7.6	45			Y
7		7.4	40			Y
11		7.9	45			Y
14		7.8	45			Y
15		7.5	40			Y
16		7.6	40			Y
18		7.4	40			Y
21		7.7	40			Y
25		7.7	40			Y
26		7.8	40			Y
29		7.5	40			Y

(N = No = Excursion)

**Total N's**

0

<Has sample met the minimums?

**ENTRY POINT**

PWS ID: 41

System Name: Johnson Creek

Sample Period: September 2023

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

Print Name: JJ Olson

Signature: Jeffrey Olson

Date: 10/06/2023

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>