

Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
1		7.8	50			Y
2		7.9	50			Y
4		7.9	50			Y
5		8.0	50			Y
6		7.8	45			Y
7		8.0	50			Y
8		8.1	55			Y
10		7.9	50			Y
16		7.9	45			Y
18		7.9	45			Y
21		7.8	50			Y
23		7.8	45			Y
26		7.7	45			Y
28		7.8	50			Y
29		7.8	50			Y
31		7.8	50			Y

(N = No = Excursion)

Total N's

0

<Has sample
met the
minimums?

ENTRY POINT

PWS ID: 41

System Name: Johnson Creek

Sample Period: July 2025

Number of excursions during this
Sample Period = 0

(Number of locations when any WQP
was less than the minimum.)

Note: Entry Point and Distribution
Excursions are cumulative. Add Entry
Point and Distribution Excursions to get
total for sample period.

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Curtis Olson

Signature: Curtis Olson

Date: 08/10/2025

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>