

Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	рН	Alk	PO4	other	Y/N
2		7.3	35			Y
4		7.4	35			Y
6		7.6	40			Y
7		7.9	45			Y
9		7.8	45			Y
12		7.8	50			Y
15		7.4	40			Y
17		7.3	35			Y
18		7.3	35			Y
21		7.6	40			Y
24		7.5	40			Y
25		7.7	45			Y
26		7.8	40			Y
						0

(N = No = Excursion) Total N's 0

<Has sample
met the
minimums?</pre>

ENTRY POINT

PWS ID: 41 0 1 0 7 2

System Name: <u>Johnson Creek</u>
Sample Period: <u>September 2025</u>

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only Minimum Water Quality Parameters as set by					
рН	7.2				
Alk	30.0	(Alkalinity)			
PO4		(Orthophosphate)			
Other		()			
Other					

Print Name: Curtis Olson

Signature: Curtis Olson

Date: 10/10/2025

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/