

Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
1						
2						
3						
4						
5						
6						
7						
8		7.6	50			
9		7.6	45			
10						
11		7.9	50			
12						
13						
14		7.5	45			
15						
16						
17		7.6	50			
18						
19		7.8	50			
20						
21						
22		7.6	45			
23						
24						
25		7.2	35			
26		7.4	45			
27						
28		7.3	40			
29						
30		7.5	45			
31						

(N = No = Excursion)

Total N's

0

<Has sample
met the
minimums?

ENTRY POINT

PWS ID: 41

0	1	0	7	2
---	---	---	---	---

System Name: Johnson CreekSample Period: NOV 2025

Number of excursions during this
Sample Period = 0

(Number of locations when any WQP
was less than the minimum.)

Note: Entry Point and Distribution
Excursions are cumulative. Add Entry
Point and Distribution Excursions to get
total for sample period.

For OHA use only

Minimum Water Quality
Parameters as set by

pH	7.2	
Alk	30.0	(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Curtis OlsonSignature: Curtis OlsonDate: 12/05/2025

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>