



# Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
1						
2		7.7	45			Y
3		7.8	50			Y
4						
5						
6						
7						
8						
9						
10						
11		7.5	50			Y
12						
13		7.6	50			Y
14						
15						
16		7.7	55			Y
17		7.8	55			Y
18						
19						
20						
21						
22		7.6	50			Y
23						
24						
25		7.4	40			Y
26						
27						
28						
29						
30		7.6	45			Y
31		7.6	50			Y
(N = No = Excursion) <b>Total N's</b>						0

<Has sample met the minimums?

**ENTRY POINT**

PWS ID: 41

System Name: Johnson Creek

Sample Period: DEC 2025

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="30.0"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Curtis Olson

Signature: Curtis Olson

Date: 01/10/2026

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>